AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

	AMENDMENT OF SOLIC	II A I IOW	ODIFICAL	ON O	CONTRACT			
						1. PAGE	1 OF 12 PAGES	
2. AM ENDM	ENT/MODIFICATION NO.:	3. EFFECTIVE DATE	4. PURCHASE REQUISITI		5A. SOLICITATION/CONTRACT/PR	OJECT TITLE	1	
	002	5DEC2005	NA		5B. PROJECT NO (Ifapplicable)			
6. ISSUED B	ARCHITECT OF THE CAPITO United States Capitol Washington, D.C. 20515	L		Arch Procu Ford Attn:	RESS AMENDMENT/MODIFICATION 7 itect of the Capitol trement Division House Office Building, Room H2-263 CAROLYN HORNE (202) 226-1940 and "D" Streets, S.W. tington, DC 20515	0		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code) TO ALL CONTRACTORS				(X)	9A. AMENDMENT OF SOLICITATION NO. AOC 050104			
					9B. DATED (See Item 11) 11OCT2005			
					10A. MODIFICATION OF CONTRACT/ORDER NO.			
					10B. DATED (See Item 13)	n 13)		
	11. THI	S ITEM APPL	IES ONLY TO	AMEND	MENTS OF SOLICITATIONS			
(a) By comple (b) By acknow (c) By separat FAILURE O SPECIFIED 1 each letter main	ting Items 8 and 15, and returning 1 wledging receipt of this amendment in Blo- te letter which includes a reference to the DF YOUR ACKNOWLEDGMENT TO	copies of the ame ck 12 of the AOC 3 solicitation and am BE RECEIVED 2 DUR OFFER. If by nendment, and is re	ndment; 3 or Block 19 of the endment numbers. AT THE PLACE I virtue of this amenda	e AOC 144 DESIGNA' ment you de	e solicitation or as amended, by one of the f 2 of the original solicitation package, givin TED FOR THE RECEIPT OF OFFERS estire to change an offer already submitted, su eipt hour and date specified.	g amendment n	number and its date; or THE HOUR AND DATE	
	13. THIS ITEM	A APPLIES ON	LY TO MODIE	ICATIO	NS OF CONTRACTS/ORDERS A	ND		
					AS DESCRIBED IN ITEM 14.			
Check One	A. THIS CHANGE ORDER IS ISSUE NO. IN ITEM 10A.	D PURSUANT TO	: (Specify authority) THE CH	ANGES SET FORTH IN ITEM 14 ARE N	IADE IN THE	CONTRACT/ORDER	
	B. THE ABOVE NUMBERED CONT appropriation date, etc.) SET FORTH IN				HE ADMINISTRATIVE CHANGES (such OF FAR 43.103(b)(1)	as changes in	paying office,	
	C. THIS SUPPLEMENTAL AGREEM	ENT IS ENTERED	INTO PURSUAN	T TO AUT	CHORITY OF:			
	D. OTHER (Specify type of modification and authority)							
E. IMPORTA	NT: Contractor $\{-}$ is required to sig	n this document and	l return it to the issu	ing office.				
14. DESCRIF	TION OF AMENDMENT/MODIFICAT	ION						
receipt of	proposals has been extended as	stated in bloc	k 11 above.	SEE C				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.								
15A. NAME	AND TITLE OF SIGNER (Type or print)			16A. NA	AME OF CONTRACTING OFFICER (Ty	pe or print)		
15B. OFFER	OR/CONTRACTOR	15C.	DATE SIGNED	16B. U	NITED STATES OF AMERICA		16C. DATE SIGNED	
				Bv				

(Signature of Contracting Officer)

(Signature of person authorized to sign)

QUESTIONS/ANSWERS

1. Is interior and exterior window cleaning part of the base contract or is it reimbursable? What is the frequency required?

YES. Frequency is Quarterly.

2. Is the cost of materials and parts needed for the repair of the equipment, reimbursed to the contractor?

YES

3. Are consumables such as filters reimbursed to the contractor?

Yes. There is a separate line item for spare parts, etc. reimbursable.

4. Is there a contractor financial threshold on this contract?

Question not understood!

5. Is attachment J-15 to be filled out and returned with sections B, L, & M?

YES

6. Will training be provided by construction contractors?

NO

7. Can a list of installing contractors be provided for the following systems, fire alarms, and DC environmental control?

NO

8. Who is the manufacturer of the PM system required software FC CAFM?

FC CAFM is not required. Please refer to question 6 above. TRI RIGA is the developer of the FC CAFM software the Government is presently using.

9. Who is responsible for providing this software? Who will provide the associated hardware to run the system?

Please refer to the listing of items, equipment, and materials to be provided by the government.

10. Will access to the building DDC system be provided for off-site monitoring and control?

NO

QUESTIONS/ANSWERS

11. Will office space be provided?

NO

12. Will phone, fax, and network communications be provided?

YES...however, only local phone service will be provided.

13. Will time and material be reimbursed to the contractor, which are a direct result of warranty and preexisting deficiencies?

The resultant contract does not include a line item for time/materials.

14. Is all cleaning to be performed on Monday & Wednesday within a 3-hour period each day?

Only routine weekly cleaning is required to be performed between the hours of 1 and 4 assuming it can all be done. Monthly and annual cleaning shall be coordinated with occupants as required.

15. Will the government be providing a trash dumpster and waste baskets for the custodians use?

YES

16. Are any custodial supplies reimbursable on this contract?

NO

17. SOW section C.4.9 states that normal hours of operation are 6 am to 6 pm, Mon-Fri. Is the contractor required to staff any or all functions during all normal working hours (i.e., 50-hours per week) This question does not apply to 24/7 positions).

No. The intention of this statement is to let the contractors be aware of the typical occupancy hours for the facility. These are the hours the contractor should anticipate trouble calls for things like—to hot/to cold, lights out, stopped up toilet, or power out.

18. SOW Section C.4.20 states that all parts, materials, supplies, and equipment purchased on a cost reimbursable basis shall become the property of the government. Will the contractor be allowed to invoice for reimbursement at the time of purchase versus time of use?

Please read section B.2.5.

19. SOW section 4.20 states that consumables purchased by the Contractor (parts crib) will be turned over to the government at the expiration of the contract. Please clarify that this statement applies only to those materials for which the Government has actually reimbursed the contractor for.

QUESTIONS/ANSWERS

Please read section B.2.5.

20. Please clarify the first full sentence on page 21 of 30 of the SOW-C.6.1.

See Section J, ATTCH 7 for an estimate (contractor finale detailed inventory in CAFM) of mechanical electrical and plumbing system that require maintenance.

Attachment 7 is an estimate of mechanical electrical and plumbing system that requires maintenance. This estimate was derived from a set of working drawings during construction of the facility. The facility was

completed 1OCT05. We called this an estimate for the following reason: during construction, the contractor may have added sprinkler heads or lights to meet a code regulation that the drawings failed to identify, our estimate of the lights was simply counting the number of lights on the drawings. The contractor is responsible for accurately counting all items in the facility to be maintained and entering them into the CAFM software.

21. Will the contractor have access to the government CAFM system or will the contractor be required to provide it? What system and version of the CAFM system are we required to use?

The contractor can have access to the Government CAFM software if they choose to do so: The following are some of the reasons for access: The Contractor must---- sign any security policy related to accessing the AOC network; have access to a broadband network from home or office, such as a cable modem or dsl modem; have a computer capable of accessing the internet through his home computer and allow a small security application to install in order to use our remote access web site; have a computer running any version microsoft XP operating system; be willing to utilize our CAFM system to track his work, such as Facility and/or TMA systems; comply with all AOC policy standards related to accessing our internal network; submit all changes to the CAFM database to the COTR in writing and a copy in electronic format (word, excel). This will include the initial downloading of assets and procedures to maintain the systems at the facility. The Government cannot guarantee the work order can be printed from the contractor's remote workstation. It will be up to the contractor to purchase the required hardware and/or software to make this happen. Recommendations for hardware and software will be provided to the contractor after contract has been awarded. The contractor can provide their own CAM software brand or manufacture. The only requirement of the software is that it produces demand and planed work orders that can be tracked in a database. All assets must be entered into the database and the database should be maintained by the contractor.

22. Will the contractor have access to the Government drafting software system or will the contractor be required to provide it? What system and version of the software drafting software are we required to use?

The contractor will not have access to the Government drafting software system. The contractor can utilize any drafting software package which can generate scalable drawings. Two examples are Autocad and Microstation. The software should have the ability to generate a universal file for Microstation, such as dxf file format.

QUESTIONS/ANSWERS

23. Will the server which the CAFM and drafting software will use be government provided or contractor furnished?

The contractor shall be responsible for providing own computer hardware for all computer applications.

24. Does the government have plans to put water softening/treatment systems in place?

NO

25. Will the contractor be required to oversee services provided by government-directed subcontractors such as security systems support and telecommunications (wiring, connections, and equipment)?

NO

26. In reference to regulation VAC 25-200-10, we are required to provide 1 VA Dept of Environmental Quality water withdrawal report per well. Does this facility use well water?

NO...disregard references to wells.

27. Could the Government provide a clarification as to the required skill sets to be onsite on a 24/7 basis?

The contractor shall furnish the COTR with a staffing plan per Section J, ATTCH 5 Schedule of Deliverables. It will include the resume's of all key personnel for approval. During the project life, changes to key personnel shall require COTR approval prior to use on the contract. The COTR shall have the right to reject any proposed replacement staff and request another replacement. For the life of the project, the following is a list of other personnel/skills that are required to support the project, general maintenance mechanics, contracts coordinator, and logistical support/procurement. The above list in no way limits the number or type of personnel and subcontractors that may be needed for the performance of the work, nor does it imply that a dedicated employee must be furnished for each of the skills required by this paragraph. The staffing plan should also show shifts for 24/7 coverage (key personnel on call). The contractor needs to have access to key personnel 24/7 to address concerns with mechanical, fire, and electrical systems at the facility.

28. We assume FC CAFM refers to Facility center. Which version is to be used? Will AOC provide a server and access or will the contractor be required to provide the server and software?

The contractor is not limited to Facility center if they are purchasing their own maintenance software. See Government Furnished Equipment, materials, and/or facilities.

29. Section A of the RFP indicates that Section E and F are part of the RFP; however, they are not included within the download of the RFP.

References to these sections are hereby deleted.

QUESTIONS/ANSWERS

30. If the DDC system is to be monitored locally, then please provide information for the type of system (manufacturer) model and any required additional software to perform this task.

The two DDC systems we have are Trane-Tracer and Stulz Air Tech Systems. All DDC controls can be viewed locally. Software to interface with the DDC will be provided as needed.

31. Section C. 6. 3. Temperature requirements: Please provide the allowable variances from set point for the temperatures required in the listed spaces.

Rooms 127, 128, 123, and 125 (+ or – 5 Degrees). Rooms 127, 128, 125 + or – 5 % RH Room 123 + or – 3%

Rest of the building is + or - 5 Degrees.

32. Are consumable materials required to be purchased and funded by the contractor as part of the quote? Examples: light bulbs, air filters, water filters, etc.

No.

33. Water treatment: Please provide requirements for water treatment.

Not a part of the solicitation.

34. Will any of the shelves in the warehouse require dusting? If so, will it only be the first 3 shelves or higher?

All Shelves will require dusting.

35. Will there be any lifts or items in the way at the beginning & end of each row that would prevent us from using a walk behind scrubber on the floors?

No.

36. Is there anything special about the floor in the Server room. Is it raised, with cables underneath the floor? Anything that would prevent us from using the normal amount of water we usually use to clean floors?

No.

37. On the plans, I counted 4 restrooms and one shower room. Is this correct?

Yes.

QUESTIONS/ANSWERS

38. Will there be a janitor's closet with a mop sink where we can store a walk behind floor scrubber & cleaning supplies?

Yes.

39. Will there be any shelf room for storing toilet paper, paper towels, or soap refills for the bathrooms?

Yes

40. Have you come to a decision or found out additional information regarding the possible extension.

Extension was approved.

41. As previously stated, without sufficient information regarding the (1) contractor space; (2) storage space, (3) equipment listing; etc....there are really too many unknowns for the contractor to present an adequate bid.

Contractor will not be provided with an office space at the site. Storage space is limited to mechanical rooms.

42. RFP Section L.14.2.1 states that sections A and K of the RFP must be submitted as part of Volume 1 - solicitation, offer, and award form. However, RFP Section L.14.3 states that sections A and K must be submitted as part of Volume 3 - cost proposal. Please clarify which volumes are to contain completed sections A and K of the RFP.

Completed Sections A and K shall be included within Volume 1; while completed Section B and Attachment J-15 shall be included within Volume 3.

43. RFP section L.14.2.1(2) refers to Attachment 1, Mandatory requirements". We were not able to locate this attachment.

Solicitation references to this requirement is hereby deleted.

44. Please provide details of the FM200 systems, including the number or cylinders per system, the number of annunciators per system and the quantity of the following devices per system: ceiling smoke detectors, above ceiling smoke detectors, under-floor smoke detectors, manual pull stations, abort stations, smoke detectors, duct detectors, horn-strobes, bells, and strobes.

Assume two tanks per system. See material list Q-46.

45 Is the building annunciator panel located next to the building fire alarm panel or in another location? If in another location, can the building fire alarm system be reset from the annunciator panel?

Yes. The annunciator panel is at the main entrance. Yes, you can reset.

QUESTIONS/ANSWERS

46. Attachment J7 estimates five pre-action valves. Can this number be verified? How many smoke detectors pull stations, horn-strobes, bells or strobes are associated with each of the pre-action systems?

See material list below.

QUESTIONS/ANSWERS

A.O.C. WAREHOUSE BUILDING E CABIN BRANCH DISTRIBUTION CENTER

FIRE ALARM SYSTEM

WANTITY Y	DESCRIPTION	MODEL.	
	No.		PAGE
1	CONTROL PANEL	AFP-200	1
]	SURGE SUPPRESSOR	D1K-2LVP24F	2
2	BATTERY	PS-12120	3
1	COMMUNICATOR	911AC	4
1	BATTERY	PS-1250	5
1	A/V POWER SUPPLY	FCPS-2486	6
2	BATTERY	PS-1270	7
1	ANNUNCIATOR / DRAWING	LCD-80TM / DWG	g
19	SMOKE DETECTOR (ION)	FSI-851 / B710LP	9
20	SMOKE DETECTOR (PHOTO)	FSP-851 / B710LP	10
20	DUCT SMOKE DETECTOR (WITH)	FSD-7510	11
	(I) REMOTE INDICATOR	RA400Z	1.1
	(I) SAMPLING TUBE	ST-5	
8	MANUAL STATION	NBG-12LX	10
31	MONITOR MODULE	FMM-1	12 13
21	RELAY MODULE	FRM-1	
1	ATTEC CARE THE CARE A CONTRACT OF THE CONTRACT	AHU SW	14
2	COMP CONT. CO. C.	MDL	15
26		S1224MC	16
	(9) @ 15 CANDELA		17
	(2) @ 30 CANDELA		
	(1) @ 75 CANDELA		
	(14) @ 110 CANDELA		
35	FTOTO 1 1	P1224MC	17
	(10) @ 15 CANDELA	1 1224WK	17
	(I) @ 30 CANDELA		
	(2) @ 75 CANDELA		
	(22) @ 110 CANDELA		
	() 6		
	EQUIPMENT FURNISHED BY	OTHERS	
2	PRE ACTION PANEL		
2	SIGNAL HORN		
2	ABORT STATION		
	PRE ACTION VALVE		
	MANUAL RELEASE STATION		
	GENERATOR / CONTROL PANEL		
	THE PERSON NAMED IN TAKEN		
	SPRINKLER FLOW SWITCH		
I	SPRINKLER FLOW SWITCH VALVE TAMPER SWITCH		

47. Attachment J7 estimates a total of twelve sprinkler valves in the building. Can this number be verified?

QUESTIONS/ANSWERS

Assuming that there are five pre-action valves, and one alarm valve serving the building, what do the other six valves serve?

See material list Q-46

48. Do the devices listed on Attachment 7 include the devices associated with the FM 200 and pre-action sprinkler systems?

Devices listed in Attachment 7 associated with the fire alarm panel can be replaced by the material list in Q-46.

49. Is there only one flow switch serving the building sprinkler system? How many tamper switches serve the building sprinkler system?

See material list Q-46.

50. There should be one pressure switch per pre-action system, as well as one hi-lo air switch. How many tamper switches are there on each pre-action system?

See material list Q-46 for quantity of tamper switches.

51. There are no quantities shown for duct detectors. How many duct detectors are there in the building?

See material list Q-46.

52. Are there detectors (smoke detectors, duct detectors, heat detectors) that are above 12' that would require a lift or a ladder to reach? If so, how many of each detector are above 12'?

Assume all detectors are above the 12' height. See material list for quantity.

53. What is the manufacturer and model of the fire alarm system?

Notifire AFP-200.

54. The solicitation asks for spare parts. What are the make and model numbers of the fire alarm devices outlined on Attach J-8?

The requirements for gathering the asset information are part of the solicitation and should be field verified by the contractor. See material list Q-46.


55. Who is the manufacturer of the Control System?

See response to Q-30.

QUESTIONS/ANSWERS

56. Please give details on the grease and oil interceptor (Attachment J6, Page 2)?

(See below)



QUESTIONS/ANSWERS

57. Please give the Quantity of motorized Overhead Doors?

Twenty (22).

58. Please give the names of the contractors who installed the FM-200 system, sprinkler system, control system and HVAC equipment?

FM-200: See Q-23

Sprinkler System: Unknown at this time

Control System: See Q-23

HVAC: See Q-23

59. Does the government have a particular CMMS that they would like the contractor to use?

No.

END OF QUESTIONS/RESPONSES